

Brittany Bermingham

Forwarded on 5.1.18
to: R. Pearson
T. Dumas

From: Mike Sinsigalli
Sent: Thursday, April 26, 2018 11:18 AM
To: Brittany Bermingham
Subject: RE: 1344 New Britain Ave- SDD Plans for Comments

Follow Up Flag: Follow up
Flag Status: Flagged

Brittany,

Review of the site plan for fire department access disclosed the following:

1. New multiple family residential buildings are required to be sprinkler protected. The arrangement of the parking does not provide access to points of the building where Fire Department Sprinkler Connections can be accessed.
2. The closest fire hydrant is located on Berkshire Road, at the west side of the road at the intersection with New Britain Avenue. The use of this hydrant will require the closing off of Berkshire Road to traffic, including other responding fire units, because of the need to extend supply hose across the street. We are requesting that an additional fire hydrant be provided on the east side of Berkshire Road, just north of the driveway into the site.

Please contact me with any questions.

Michael Sinsigalli
Assistant Fire Chief
West Hartford Fire Department
860-561-8308

The fire that you prevent may be the one that would have taken your life!

Please note email address change to msinsigalli@westhartfordct.gov

[Follow Us](#)

From: Brittany Bermingham
Sent: Wednesday, April 25, 2018 11:20 AM
To: John Phillips <JohnP@WestHartfordCT.gov>; Tim Mikloiche <TMikloiche@WestHartfordCT.gov>; Mike Sinsigalli <MSinsigalli@WestHartfordCT.gov>; Dan Coppinger <DCoppinger@WestHartfordCT.gov>
Subject: 1344 New Britain Ave- SDD Plans for Comments

Please see the plans attached, which I had to condense to email over. Let me know if you need to see landscaping and architectural plans as well.

Brittany A. Bermingham
Planning Technician
Town of West Hartford
Department of Community Development: Planning & Zoning Division
50 South Main Street, Room 214 | West Hartford CT 06107 | t 860.561.7555 | f 860.561.7504
brittany.bermingham@westhartfordct.gov